CERTIFICATE



0036 CPD 9174 026

Revision 02

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21st December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD) amended by the Directive 93/68/EEC of the Council of European Communities of 22nd July 1993, it has been stated that the construction product

Connecting flue pipe type EW-FU models

Model 1	
DN 80 - DN 120	EN 1856-2 T400 N1 D V2 L50060 G375 NM
DN 130	EN 1856-2 T400 N1 D V2 L50060 G390 NM
DN 140 - DN 600	EN 1856-2 T400 N1 D V2 L50060 G400 M
Model 2	
DN 80 – DN 120	EN 1856-2 T400 N1 W V2 L50060 O375 NM
DN 130	EN 1856-2 T400 N1 W V2 L50060 O390 NM
DN 140 - DN 600	EN 1856-2 T400 N1 W V2 L50060 O400 M

produced by

Jeremias GmbH Opfenrieder Straße 11-14 91717 Wassertrüdingen

in the factories

Jeremias	Jeremias Polska	Jeremias España	Jeremias CZ
D-91717	PL-62 200	ES-48340	CZ-434 01
Wassertrüdingen	Gniezno	Amorebieta	Most Rudolice

is submitted to

- the initial type testing, performed by TÜV SÜD Industrie Service GmbH, test reports A 1670-00/07, A 1670-01/11 and A 1670-02/12 as well as
- a factory production control

The Notified Body TÜV SÜD Industrie Service GmbH has performed the initial inspection of the factory and the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of factory production control described in Annex ZA of the standard

EN 1856-2: 2009-06

were applied.

This certificate was first issued on 2008-04-03 and - with respect to the conditions of the certification contract - remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Munich, 2012-09-13

J. Steiglechner